

# **A SAMPLE OF UNCERTAINTY ANALYSIS ON FIELD PERFORMANCE TEST**

**By Albert F. Mikhail, P.Eng., Ontario Power Generation  
IGHM 2002 TORONTO**

## **ABSTRACT**

The field performance test results should have an uncertainty analysis to provide a band of acceptable data values. The uncertainty will consist of the systematic and random components. All the test result values will be acceptable within the uncertainty band. Unrealistic presentation of uncertainties will impact on confidence of the test results

There are subjective and objective measures of the uncertainties. The requirement of an objective measures of uncertainties are very important to establish a true value of the test data accuracy.

A subjective reasoning of uncertainties may describe the measured data as “accurate”, “right on”, “astonishing close”, “highly accurate”.

The objective uncertainty evaluation can be described as the basic concept of elemental uncertainty analysis which consist of two parts, the random uncertainties (Precision), and the systematic uncertainties (bias).

The concept of analyzing both uncertainties combined together (random and systematic) to a single number to describe measurement uncertainties which combine the effect of precision and bias.

This is an attempt to apply the IEC test code uncertainties definitions in a practical way to evaluate the field test uncertainties.

This paper will present the measurement elements of a field performance test. The Flow was measured by the Pressure Time Method using the Gibson Instrument. The head, output and wicket gate opening were measured by high accuracy instrumentation.

## 1. MEASUREMENT OF FLOW (GIBSON PRESSURE-TIME METHOD)

The following uncertainty analysis is prepared according to the test codes IEC - 41, and ASME PTC 18-1992

The uncertainties, both systematic and random, associated to the measurement of flow are dependent on the measurement of many parameters as described below. Table 1 presents a summary of the uncertainty values associated with the measurement flow. While, the detailed analysis of flow uncertainty is presented in Table 2.

In the uncertainty analysis the following parameters are used

	Description	Units
$A_{GIBSON}$	net area of the Gibson diagram	in <sup>2</sup>
$e_r$	Random error	
$e_s$	Systematic error	
$e$	Total Uncertainty = $(e_r^2 + e_s^2)^{1/2}$	
F	pipe factor	ft <sup>-1</sup>
$g$	gravitational acceleration	m/sec <sup>2</sup>
K	Gibson Instrument Constant	
M	Specific gravity of mercury	lb/ft <sup>3</sup>
$P_{DIA}$	Penstock Diameter	metres
$P_{LG}$	Distance Between Gibson Piezometer Taps	metres
Q	turbine flow	m <sup>3</sup> /s
$Q_{LEAKAGE}$	Leakage from the wicket gates	ft <sup>3</sup> /s
R	Ratio of cross sectional area of glass tube to area of the riser of Gibson Instrument	
S	Time constant of Gibson Diagram	inches

## 2. Calibration of the Gibson Instrument (K)

The Gibson Instrument was calibrated before the tests. The calibrations were carried out at our facilities to determine the Gibson Instrument Constant. The uncertainty of the Gibson instrument consists of the following elements.

## 3. Determination of the Acceleration due to Gravity (g)

The acceleration of gravity is calculated from the standard acceleration due to gravity and adjusted to the proper latitude and altitude. The systematic uncertainty is based on IEC code recommendations.

## 4. Determination of the Specific Gravity of Mercury (M)

The mercury specific gravity was measured by an independent laboratory and found to be 13.5757 lb/ft<sup>3</sup> at 25° C. The specific gravity was adjusted to 13.5749 lb/ft<sup>3</sup> at 20°C.

## **5. Ratio of Areas - Two Legs of the Gibson Apparatus Manometer Tubes (R)**

The Gibson Apparatus is fabricated with very high precision. The Gibson instrument was calibrated immediately before the test using a micrometer and a precise pressure source.

## **6. Pipe Factor (F)**

## **7. Penstock Diameter Measurement ( $P_{Dia.}$ )**

The penstock diameter was measured using a surveying technique with checking the upper and lower piezometer taps using a custom made micrometer. The measurement was carried out by Remote Access Technology. Analysis and computations were undertaken by Capital Projects Group Inc. (CPG Inc.)

## **8. Measurement of distance - Upper and Lower Gibson Piezometer Taps ( $P_{LG}$ )**

Measurement of distance between the upper and lower piezometer taps uncertainties are from the measuring Tape length uncertainty (100 ft), Thermal Expansion & Contraction, Measuring procedure

## **9. Leakage Past Turbine after Gate Closure ( $Q_{LEAKAGE}$ )**

The uncertainty arising from determining the leakage through the wicket gates after the closure of the gates. The uncertainty is a function of the gate clearance area calculations and the coefficient of flow.

## **10. Setting up the Lens of the Gibson Apparatus**

The setting up of the lens of the apparatus to produce a 1 to 1 ratio of object and image. The Gibson instrument is built with a very high level of precision. The lens was calibrated, following uncertainties were determined during this calibration process:

## **11. Time Measurement by the Suspension Rod of the Pendulum (S)**

The uncertainty is determined by measuring the time lines on the diagram.

## **12. Determining the Gibson Diagram Area ( $A_{GIBSON}$ )**

The uncertainty evaluation depends on the digitizer accuracy, print correction factor and integration techniques and the operation of digitizing. The uncertainties associated with each of these factors are described below.

## **13. Digitizer Accuracy**

Accuracy was specified by the digitizer manufacturer.

#### **14. Print Correction**

The print correction factor is determined by comparing four corners on the film to the same four points on the print.

#### **15. Integration Techniques**

Determining the area under the pressure wave diagram, the starting and diagram ending points, the harmonic effect, and the method of fitting a graph to the digitized data.

#### **16. Digitizing Technique**

The uncertainty from the actual digitizing, the number of digitized points, the selection of the location of the points, etc.

#### **17. "Nebenbewegungen" or Conduit Friction Tolerance**

Accessory motion of the water column in the penstock as per ASME Paper 58-A-78.

#### **18. Friction in the Mercury Manometer**

Mercury column friction in the manometer, as per ASME paper 58-A-78

#### **19. Inertia of the Mercury**

Mercury column inertia in the mercury manometer, as per ASME paper 58-A-78.

#### **20. Elasticity, Water Pulsation, and Reflected Waves in the Penstock**

As per ASME paper 58-A-78.

#### **21. MEASUREMENT OF HEAD**

The uncertainties, both systematic and random, associated to the measurement of head depend on the measurement of elevation and pressure as described in the following sections. The uncertainties associated with head measurements, are summarized in Tables 1, while, Tables 3 and Table 4 present a detailed computation of the uncertainty.

#### **22. MEASUREMENT OF GENERATOR OUTPUT**

The uncertainties, both systematic and random, associated to the measurement of generator output depend on the measurement of generator output, generator losses and the phase shift as summarized in Tables 1. These uncertainties are included in the analysis of turbine and overall unit results, Tables 5 and 6.

### **23. UNCERTAINTY OF TURBINE AND OVERALL UNIT RESULTS**

The uncertainties associated with the test results are dependent on all parameters measured. For turbine results these include flowrate, net head, turbine power output, and wicket gate opening. Tables 5 provide a detail of the analysis of the uncertainty attributed to the turbine results. The overall unit results are dependent of the measurement of flow, gross head, generator output and wicket gate opening. Table 6 provides a detail of the analysis of the uncertainty attributed to the overall unit test results.

**TABLE 1 SUMMARY OF UNCERTAINTY ANALYSIS VALUES**

Ontario Power Generation Inc.  
 Sir Adam Beck G.S. II  
 Unit #26

**DATA INPUT**

Normalized Gross Head	89.00	metres	
Normalized Net Head	87.80	metres	
Q=Average Flow near Best Efficiency	102.61	m <sup>3</sup> /sec	
Full Servometer Stroke	332.02	mm	
Turbine Output at Best Efficiency	84.55	MW	
Unit Output at Best Efficiency	80.54	MW	
Gravity	9.808531354	m/sec <sup>2</sup>	32.1804 ft/sec <sup>2</sup>
Mercury Specific Gravity	13583		13.5778
Distance Between Upper and Lower Taps	21.84996595	m	71.6862 ft
Leakage Flow	0.795593007	m <sup>3</sup> /sec	27.7467 cfs
Total Leakage Area	0.019045196	m <sup>2</sup>	0.205 feet <sup>2</sup>
Wicket Gate Circumference	15.42066462	m	607.113 in

		Systematic Uncertainty		Random Uncertainty	
<b>FLOWRATE</b>					
1.1.1	Acceleration due to Gravity	+ 0.0500	% of flow	e	
1.1.2	Specific Gravity of Mercury	+ 0.1000	% of flow	e	
1.1.3	Ratio of Areas - Two Legs of the Gibson Apparatus Manometer Taps	+ 0.1000	% of flow	e	+ 0.013380 %
1.2.1	Penstock Diameter Measurement	+ 0.10000	feet	d	+ 0.164400 %
1.2.2	Length between Upper & Lower Gibson Taps	+ 1.4893	feet	d	+ 0.081390 %
1.3	Leakage Past Turbine after Gate Closure	+ 0.2500	inches	e	
1.4	Lens of the Gibson Apparatus	+ 0.0500	%	?	
1.5	Time Measurement by the Suspension Rod of the Pendulum	+ 0.0500	%	d	+ 0.080000 %
1.6.1	Digitizer Accuracy	+ 0.1000	%	d	
1.6.2	Printing Correction	+ 0.0500	%	e	
1.6.3	Integration Techniques	+ 0.0800	%	e	
1.6.4	Digitizing	+ 0.5000	%	e	+ 0.750000 %
1.7	Nebenbewegungen* or Conduit Friction Tolerance	+ 0.1500	%	e	
1.8	Friction in the Mercury Manometer	+ 0.1250	%	e	
1.9	Inertia of the Mercury	+ 0.0600	%	e	
1.1	Elasticity, Water Pulsation, & Reflected Waves in the Penstock	+ 0.0500	%	e	
<b>HEAD</b>					
2.1	Station Headwater (% of IR psi)	+ 0.100	% of 10	d	+ 10.0 mm
2.2	Station Tailwater (% of IR in psi)	+ 0.100	% of 10	d	+ 10.0 mm
2.3	Vertical Control Survey (mm)	+ 1.0	mm	d	+ 3.0 mm
2.4	Net Head Measurement (% of IR in psi)	+ 0.050	% of 100	d	+ 25.0 mm
2.5	Unit Tailwater (% if IR in psi)	+ 0.100	% of 5	d	+ 10.0 mm
<b>OUTPUT</b>					
3.1	Generator Output	+ 0.050	% of measurement	d	+ 2.0 kW
3.2	Generator Losses Values	+ 0.100	% of measurement	d	+ 2.0 kW
3.3	Phase Shift	+ 0.100	% of measurement	d	+ 1.0 kW
3.4	Transformer Inaccuracies	+ 0.400	% of measurement	d	+ 2.0 kW
<b>WICKET GATE OPENING</b>					
	Wicket Gate Opening (% of IR)	+ 0.050	% of 1000	d	+ 0.50 mm

e - estimated  
 d - determined

kW - kilowatt  
 mm - millimeter

IR - instrument range

**TABLE 2 SUMMARY OF UNCERTAINTY ANALYSIS VALUES**

Ontario Power Generation Inc.  
 Sir Adam Beck G.S. II  
 Unit #26

Gravity 32.18043 ft/sec<sup>2</sup>  
 Mercury Specific Gravity 13.57783  
 Average Discharge (Q) 102.6 cfs  
 Distance Between Upper and Lower Taps 71.68624 ft  
 Leakage Flow 27.74669 cfs  
 Total Leakage Area 0.205001 0.21  
 Wicket Gate Circumference 607.1128 in

**FLOW UNCERTAINTY ANALYSIS**

References	DESCRIPTION	SYSTEMATIC UNCERTAINTY				RANDOM UNCERTAINTY			
		Uncertainty		es	es <sup>2</sup>	Uncertainty		er	er <sup>2</sup>
			% of Q				% of Q		
1.1.1	Acceleration due to Gravity	0.05000 %		0.05000	0.002500				
1.1.2	Specific Gravity of Mercury	0.10000 %	0.10000	0.09745	0.009497				
1.1.3	Ratio of Areas - Two Legs of the Gibson Apparatus Manometer Tubes	0.10000 %	0.10000 m/sec	0.09745	0.009497	0.013380 %	0.01338 %	0.01338	0.000179
1.2.1	Penstock Diameter Measurement	0.10000 ft	m/sec			0.164400 %	0.16440 %	0.16440	0.027027
1.2.2	Length between Upper & Lower Gibson Taps	1.48930 ft	1.84792 m/sec	1.80084	3.243037	0.081390 %	0.08139 %	0.08139	0.006624
1.3	Leakage Past Turbine after Gate Closure	0.25000 %	0.00494 m/sec	0.00482	0.000023				
1.4	Lens of the Gibson Apparatus	0.05000 %	0.05000 m/sec	0.04873	0.002374				
1.5	Time Measurement by the Suspension Rod of the Pendulum	0.05000 %	0.05000 m/sec	0.04873	0.002374	0.080000 %	0.08000 %	0.08000	0.006400
1.6.1	Digitizer Accuracy	0.10000 %	0.10000 m/sec	0.09745	0.009497				
1.6.2	Printing Correction	0.05000 %	0.05000 m/sec	0.04873	0.002374				
1.6.3	Integration Techniques	0.08000 %	0.08000 m <sup>2</sup>	0.07796	0.006078				
1.6.4	Digitizing	0.50000 %	0.50000 m/sec	0.48726	0.237423	0.750000 %	0.75000 %	0.75000	0.562500
1.7	Nebenbewegungen" or Conduit Friction Tolerance	0.15000 %	0.15000 m/sec	0.14618	0.021368				
1.8	Friction in the Mercury Manometer	0.12500 %	0.12500 m/sec	0.12182	0.014839				
1.9	Inertia of the Mercury	0.08000 %	0.08000 m/sec	0.05847	0.003419				
1.1	Elasticity, Water Pulsation, & Reflected Waves in the Penstock	0.05000 %	0.05000						
Sums of the Squares				3.56430				0.60273	
Square Root of the Sum of the Squares				(a) 1.88794				(b) 0.77636	
(c) = ( Student's t x (b) ) / sqrt(n)						Random Uncertainty at 95% Confidence = (c)		1.23518	
Student's t = 3.182								sqrt ( (a) <sup>2</sup> + (c) <sup>2</sup> )	
n = average number of replicates runs = 4						Overall Uncertainty at 95 % Confidence		2.25610	
<b>95 % CONFIDENCE</b>								<b>2.26</b>	

**TABLE 3 SUMMARY OF UNCERTAINTY ANALYSIS VALUES**

Ontario Power Generation Inc.  
 Sir Adam Beck G.S. II  
 Unit #26

Net Head instrument range 150 psi  
 Unit Tailwater instrument range 5 psi

Net Head 88.00 metres

**NET HEAD UNCERTAINTY ANALYSIS**

References	DESCRIPTION	SYSTEMATIC UNCERTAINTY				RANDOM UNCERTAINTY		
		Uncertainty		es	es <sup>2</sup>	Uncertainty	er	er <sup>2</sup>
		Instrument Uncertainty	Actual Uncertainty	% of Net Head	% of Net Head			
2.4	NET HEAD WATER LEVEL MEASUREMENT	0.05 %	0.05277 m	0.05996	0.0036	100 mm	0.11364	0.0129
2.5	UNIT TAILWATER LEVEL MEASUREMENT	0.10 %	0.00352 m	0.00400	0.0000	10 mm	0.01136	0.0001
2.3	VERTICAL CONTROL MEASUREMENT	1 mm	0.00100 m	0.00114	0.0000	3 mm	0.00341	0.0000
Sums of the Squares					0.00361	0.01305		
Square Root of the Sum of the Squares					(a) 0.06011	(b) 0.11425		
(c) = ( Student's t x (b) ) /sqrt(n)					Random Uncertainty at 95% Confidence = (c) 0.18178			
Student's t = 3.182					sqrt ( (a) <sup>2</sup> + (c) <sup>2</sup> )			
n = average number of replicates runs = 4					Overall Uncertainty at 95 % Confidence 0.19146			
<b>95 % CONFIDENCE</b>					<b>0.19</b>			



**TABLE 4 SUMMARY OF UNCERTAINTY ANALYSIS VALUES**

Ontario Power Generation Inc.  
 Sir Adam Beck G.S. II  
 Unit #26

Station Headwater instrument range 10 psi  
 Station Tailwater instrument range 5 psi

**GROSS HEAD UNCERTAINTY ANALYSIS**

Gross Head 87.8 metres

References	DESCRIPTION	SYSTEMATIC UNCERTAINTY				RANDOM UNCERTAINTY		
		Uncertainty		es	es <sup>2</sup>	Uncertainty	er	er <sup>2</sup>
		Instrument Uncertainty	Actual Uncertainty	% of Gross Head			% of Gross Head	
II-2.1	STATION HEAD WATER LEVEL MEASUREMENT	0.100 %	0.00704 m	0.00801	0.0001	10 mm	0.01139	0.0001
II-2.2	STATION TAILWATER LEVEL MEASUREMENT	0.100 %	0.00352 m	0.00401	0.0000	10 mm	0.01139	0.0001
II-2.3	VERTICAL CONTROL MEASUREMENT	1 mm	0.00100 m	0.00114	0.0000	3 mm	0.00342	0.0000
Sums of the Squares					0.00008		0.00027	
Square Root of the Sum of the Squares					(a) 0.00903		(b) 0.01647	
					Random Uncertainty at 95% Confidence = (c) 0.02620			
(c) = ( Student's t x (b) ) /sqrt(n)								
Student's t = 3.182								
n = average number of replicates runs = 4					sqrt ( (a) <sup>2</sup> + (c) <sup>2</sup> )			
					Overall Uncertainty at 95 % Confidence 0.02771			
					<b>95 % CONFIDENCE 0.03</b>			

**TABLE 5 SUMMARY OF UNCERTAINTY ANALYSIS VALUES**

Ontario Power Generation Inc.  
 Sir Adam Beck G.S. II  
 Unit #26

Net Head 88.00 metres  
 Power Output 84.55 MW  
 Average Discharge (Q) 102.6 m<sup>3</sup>/sec  
 Full Servomotor Stroke 332.0 mm  
 Servomotor Stroke instrument range 1000 mm

**TURBINE EFFICIENCY UNCERTAINTY ANALYSIS**

References	DESCRIPTION	SYSTEMATIC UNCERTAINTY			RANDOM UNCERTAINTY		
		Uncertainty	es (%)	es <sup>2</sup>	Uncertainty	er (%)	er <sup>2</sup>
TABLE 2	DISCHARGE MEASUREMENTS (GIBSON)		1.88794	3.56430		0.77636	0.60273
TABLE 3	NET HEAD MEASUREMENT		0.06011	0.00361		0.18178	0.03304
II-3.1	GENERATOR OUTPUT MEASUREMENTS	0.05 %	0.05000	0.00250	2.0 kW	0.00237	0.00001
II-3.2	GENERATOR LOSSES VALUES	0.10 %	0.10000	0.01000	2.0 kW	0.00237	0.00001
II-3.3	PHASE SHIFT	0.10 %	0.10000	0.01000	1.0 kW	0.00118	0.00000
II-3.4	TRANSFORMER INACCURACIES	0.40 %	0.40000	0.16000	2.0 kW	0.00237	0.00001
II-4	SERVOMOTOR STROKE	0.05 %	0.15059	0.02268	0.5 mm	0.15059	0.02268
Sums of the Squares			3.77309		0.65847		
Square Root of the Sum of the Squares			(a) 1.94245		(b) 0.81146		
Random Uncertainty at 95% Confidence = (c)			1.29104				
(c) = ( Student's t x (b) ) /sqrt(n)							
Student's t = 3.182							
n = average number of replicates runs = 4							
Overall Uncertainty at 95 % Confidence			sqrt ( (a) <sup>2</sup> + (c) <sup>2</sup> ) 2.33235				
<b>95 % CONFIDENCE</b>			<b>2.33</b>				

**TABLE 6 SUMMARY OF UNCERTAINTY ANALYSIS VALUES**


Ontario Power Generation Inc.  
 Sir Adam Beck G.S. II  
 Unit #26

Gross Head 87.80 metres  
 Unit Output 80.54 MW  
 Average Discharge (Q) 102.6 m<sup>3</sup>/sec  
 Full Servomotor Stroke 332.0 mm  
 Servomotor Stroke instrument range 1000 mm

**OVERALL UNIT EFFICIENCY UNCERTAINTY ANALYSIS**

References	DESCRIPTION	SYSTEMATIC UNCERTAINTY			RANDOM UNCERTAINTY		
		Uncertainty	es (%)	es <sup>2</sup>	Uncertainty	er (%)	er <sup>2</sup>
TABLE 2	DISCHARGE MEASUREMENT (GIBSON)		1.88794	3.56430		0.77636	0.60273
TABLE 4	GROSS HEAD MEASUREMENT		0.00903	0.00008		0.01647	0.00027
II-3.1	GENERATOR OUTPUT MEASUREMENTS	0.05 %	0.05000	0.00250	2.0 kW	0.00248	0.00001
II-3.3	PHASE SHIFT	0.10 %	0.10000	0.01000	1.0 kW	0.00124	0.00000
II-3.4	TRANSFORMER INACCURACIES	0.40 %	0.40000	0.16000	2.0 kW	0.00248	0.00001
II-4	SERVOMOTOR STROKE	0.05 %	0.15059	0.02268	0.5 mm	0.15059	0.02268
Sums of the Squares				3.75956		0.62569	
Square Root of the Sum of the Squares				(a) 1.93896		(b) 0.79101	
(c) = ( Student's t x (b) ) /sqrt(n)				Random Uncertainty at 95% Confidence = (c) 1.25849			
Student's t = 3.182				sqrt ( (a) <sup>2</sup> + (c) <sup>2</sup> )			
n = average number of replicates runs = 4				Overall Uncertainty at 95 % Confidence 2.31157			
<b>95 % CONFIDENCE</b>				<b>2.31</b>			

**SIR ADAM BECK G. S. UNIT # 26 POST UPGRADE GIBSON TEST**  
**OVERALL UNIT EFFICIENCY vs. GENERATOR OUTPUT ( gross head = 88.00 m )**



◆ SAB26P GEN GIBSON MEASURED TEST POINTS (TURBO-VENTS CLOSED)    — SAB26P GEN GIBSON LINE FIT (TURBO-VENTS CLOSED)